

## ADDENDUM NO. 4

### TO THE CONTRACT DOCUMENTS FOR BULK AIRCRAFT STORAGE HANGAR KEYSTONE HEIGHTS AIRPORT

September 20, 2019  
FAA No. N/A, FDOT FM No. 434911-1-94-17  
AECOM PROJECT NO.: 60589661

#### **TO: ALL HOLDERS OF CONTRACT DOCUMENTS**

1. Your attention is directed to the following interpretations of, changes in, and/or additions to the contract documents for the above named project.
2. This addendum shall be attached to the Contract Documents and shall form a part thereof.
3. Bidders are required to acknowledge receipt of this Addendum in the space provided on page P-3 of the Proposal Form.
4. The following changes shall be made:

#### **CONTRACTOR QUESTIONS/CLARIFICATIONS**

1. Contractor questions:

**Q1.** How are the louvers for this project to be broke out? The plans show six louvers and no sizes but Alternate #2 is only one exhaust fan. Please advise.

**A1.** Drawing reference C6.01. The intent of the louvers is as follows: the larger hangar alternates (Alt #1 and Alt #3) have a 80' wide back wall and will have two exhaust fans/louvers installed. The smaller hangar alternate (Alt #2) has a 60' wide back wall and will have one exhaust fan/louver installed. There is an exhaust fan go-by and accessories called out in the bottom center of Drawing C6.01: Grainger Model #7CF22 or equal with shutter wall (1C210), fan guard and wall collar (1WBV4). The price to procure and install two fans and all accessories shall be included in Bid Item #24 – 13125-H1 and Bid Item #26 – 13125-H3. The price to procure and install one fan and all accessories shall be included with Bid Item #25 – 13125-H2.

#### **ATTACHMENTS**



William R. Prange, PE  
AECOM