



**NASSAU COUNTY**  
**BOARD OF COUNTY COMMISSIONERS**  
Contract Management Department  
96135 Nassau Place, Suite 2  
Yulee, Florida 32097  
904-530-6040

Grayson Hagins  
ghagins@nassaucountyfl.com

TO: All Proposers  
FROM: Grayson Hagins, Contract/Purchasing Manager  
SUBJECT: Addendum #1  
Invitation to Bid, Bid Number NC20-014  
Fire Rescue Metal Building  
May 1, 2020

**REMINDER: This addendum must be acknowledged, on the Addendum Acknowledgment Form Attachment "D". Failure to comply may result in disqualification of your submittal.**

---

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents.

### **Part 1 – Questions/Clarifications**

Could you clarify the height of the slab relative to the existing asphalt so we can determine any cut/fill required to establish the correct slab grade? Additionally how far back from the existing asphalt should the building slab be placed to ramp down to it?

**We would like the slab to be 6in above grade. It will be approximately 6ft back from the existing slab. I would highly recommend that any one that's interested do a site visit. We don't have an elevation site plan for this property.**

The overhead doors are specified to be motorized, but you do not have any specifications for electrical service, lighting, or outlets. Please confirm if there will be any electrical scope of work for this project.

**County staff will provide the power. A 220/240 single phase motor.**

### **ATTACHMENTS:**

N/A

---

**NOTE: You are required to acknowledge receipt of this addendum on the Addendum Acknowledgment Form Attachment "D"**

**End of Addendum #1**