



**ADDENDUM NO. 1**  
**July 22, 2021**  
**CPH Project No. F11508**

500 West Fulton Street  
Sanford, Florida 32771

Phone: 407.322.6841  
Fax: 407.330.0639

**CONTRACT DOCUMENTS**  
**For**  
**Jacksonville FMS #11 Construct PEMB Parts Storage**  
**Florida Dept. of Military Affairs**  
**Project No. 12219016**

ISSUED BY

**CPH, INC.**

To: Prospective Bidders and other Concerned Parties

This Addendum No. 1 to the Plans, Specifications, and Contract Documents for the Jacksonville FMS #11 Construct PEMB Parts Storage is hereby declared a part of the Original Contract Documents. This addendum shall be incorporated within the Contract Documents and have the same force and effect as if part of the original documents, and in case of conflict, this Addendum No. 1 shall govern.

This addendum consists of the following:

- Answered questions from the Pre-Bid meeting held on July 6, 2021.
- RFI question.

**Answered questions from the Pre-Bid meeting held on July 6, 2021:**

1. Contractors cannot work on Saturdays and Sundays.
2. Contractors may be able to work on Alternate Work Schedule Mondays upon written approval by facility point of contact, MGS Wolski (or his designee).
3. Due to the unit's Annual Training Schedule, work cannot begin at the facility until 30 AUGUST 2021.

**RFI QUESTION:**

1. Plans and specs for the metal building roof call out a screw down system. A weather tightness warranty as called for in 1.04C of Division 13 specs is NOT AVAILABLE with a screw down system. A weathertightness warrantee IS available using the CFR standing seam roof system, although it is more costly. Please specify.

**Response:** Under section 1.07 Warranty: 5 year water tightness warranty will not be required.

**END OF ADDENDUM NO. 1**