

October 13, 2021

**Re-Decking of Walkways – St. Augustine Campus (SJR-BID-16-2021)  
St. Johns River State College**

Architect's Job Number: 015W08

**ADDENDUM 2**

All items in the Addendum are incorporated into the Contract Documents.

**Item 1.**

Following is a list of questions received following the issuance of Addendum No. 1:

- Q1: Sheet A-2 calls for both 5/4 and 2x material. Which material should the new surface be constructed of?  
A1: All PT decking shall be 2x material. Replace all references for PT 5/4 and change to 2x.
- Q2: Sheet A-2, Note 6 states "Provide and install weather seal on P.T. wood decking." Please provide a specification for the weather sealant to be applied to the new decking.  
A2: Weather sealant is not a required part of this contract. Remove all references to weather sealant for the PT application.
- Q3: Page A-1 General Note #6 states to 'provide weather seal on P.T. Lumber". No product specification is given in the project manual. Please specify.  
A3: See response to Q2.

End of Addendum No. 2